



Ordinance 2006-91 Exhibit I



Amendments to the:  
**2006 International Energy Conservation Code**

**Section 101.1 Title.** Insert:[name of jurisdiction] as “Pima County”.

ADD new section 101.5 to read:

**Section 101.5 Sustainable energy standard.** Compliance with the Sustainable Energy Standard shall be deemed to comply with this code.

ADD new section 302.2 to read:

**Section 302.2 Exterior design conditions.**

**Table 302.1  
 Exterior Design Conditions**

		Pima County Arizona	
CONDITION		Under 4,000 feet elevation <sup>1</sup>	4,000 feet elevation & above <sup>2</sup>
Winter	Design Dry Bulb Temp	32°F	4°F
Summer	Design Dry Bulb Temp	104°F	90°F
	Design Wet Bulb Temp	66°F	61°F
Degree days heating		2100	7000
Degree days cooling		2814	140
Climate zone		2B	5B